



Procurement Department Bid Section

April 9, 2025

ADDENDUM NUMBER: TWO (2)

TITLE: 1411963846 (IFB) JEA Fulton Cut Bulk Material Package

PROPOSAL DUE DATE: April 22, 2025

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Change:** The bid due date has been updated from ~~April 15, 2025~~ to **April 22, 2025**.

2. **Question:** What treatment and a desired species JEA would like for the wood poles?

REF NUM	QTY	UOM	DESCRIPTION
POLWO003	1	EA	35/4 Wood Pole
POLWO006	12	EA	45/3 Wood Pole
POLWO011	1	EA	60/1 Wood Pole

Answer: Southern Pine; CCA Type C.

3. **Question:** Is the “surplus” quantity to be kitted and separated from the “location” considerations and packages?

Answer: Yes, Surplus material to be separated from location material.

4. **Question:** Why is the Sediver”NON-STD0007” glass bell insulator marked in red?

Answer: Simply a note to indicate that it may be a longer lead item.

5. **Question:** We believe this is 8 25# coils- please confirm.

REF NUM	QTY	UOM	DESCRIPTION
COB TW 006	8	FT	Conductor, EC Grade #2AAC

Answer: Correct, COBTW 006 is a 25# Coil. Description below.

CONDUCTOR, #2 SOLID (AAC) TIE WIRE EC GRADE ALL- ALUMINUM 25# COIL

6. **Question:** Do you have an expectation to have the material on site?

Answer: October 2025

7. **Question:** Please confirm if these will all be delivered to one location, or if each structure will be jobsite delivered separately.

Answer: One location: 0 William Mills Street, Jacksonville FL 32226

1.3 Delivery Instructions

The project is located within Duval County in Jacksonville, FL. The project spans the St. Johns River just east of I-295 Beltway and the Dames Point Bridge.

Northbank (Blount Island/ JaxPort)

Delivery Address: 0 William Mills Street, Jacksonville FL 32226

Delivery Instructions: The Northbank of the project is located on Blount Island which is primarily the jurisdiction of the international marine port JaxPort. JEA has a transmission line right of way within the property. If delivery is through the transmission right-of-way, only contractor coordination is required. If delivery is through JaxPort, TWIC credentials are required to access through secure perimeter.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.