

JEA Brandy Branch Combined Cycle Units

SCR Lances and Sampling Grid

JEA PWO 31394786

June 9, 2025



Tom Cook  
Electric Systems Engineer

## Introduction & Background

The Brandy Branch Generating Station includes a 2x1 Combined Cycle power block that consists of two GE frame 7FA model 7341 .05 gas turbines, two Nooter-Eriksen heat recovery steam generators (HRSG), one GE D-11 steam turbine, and BOP equipment.

Units B52 & B53 combustion turbines exhaust their byproduct heat into their associated Heat Recovery Steam Generators (HRSG) for steam production for the Unit 4 steam turbine. Within the HRSG, between the HP and IP reheat sections, is a section dedicated to emissions control. Part of this section contains a Peerless Selective Catalytic Reduction (SCR) catalyst. An ammonia injection grid (AIG) is used in conjunction with the catalyst to effectively reduce NOx emissions to levels acceptable by EPA standards and permits.

This project is to upgrade both HRSG's B52 and B53, AIGs to a CECO (Peerless) Edge® square-tube lance injection system and install a sampling grid downstream of the catalyst to facilitate tuning. Additionally, all instrumentation and valves on the AIG are to be upgraded or replaced.

### A. SITE CONDITIONS

- Site location: 15701 West Beaver Street, Baldwin, FL 32234
- Equipment: Location Outdoor
- Ambient temperature range 7° to 105°F
- Site Elevation 88 feet

### B. OUTAGE DATES

- 3/26/26 to 4/4/26 Tentative availability for on-site inspection, if required.
- 3/8/27 to 4/22/27 Tentative period for AIG Lances and Sampling Grid install  
(NOTE: SCR Catalyst due to be replaced during the same outage window.  
Contractor to coordinate with SCR replacement to safely perform activities  
alongside catalyst replacement)

### C. SCOPE OF WORK

#### 1. WORK BY CONTRACTOR

##### A. AMMONIA GRID

1. Demolition and removal and disposal of existing AIG.
  - a. Procure and turnkey-install the following:
  - b. Pressure gauge near manifold inlet
  - c. Orifice plate at each branch take-off
  - d. High-Performance stainless steel throttling valve at each branch take-off
  - e. Stainless steel isolation gate valve at each branch take-off
  - f. Differential pressure indicators at each branch take-off

- g. Tubing and fittings for plumbing differential pressure indicators to orifice plates
- h. Stainless Steel Ammonia Injection Grid (EDGE™ by CECO (Peerless), contractor supplied)

**B. SAMPLING GRID**

- 1. AIG Test Grid, 2x11 Configuration
  - a. 316 SS A249 tubing
  - b. Unions, connectors
  - c. Tube supports – welded to SCR Catalyst support frame
  - d. Labels at sample terminations

**C. PROJECT COMPLETION**

- 1. Contractor shall conduct AIG tuning and performance testing to demonstrate all guarantees are satisfied.

**D. SUBMITTALS**

- 1. One electronic copy of all documents
  - a. AutoCAD and PDF all drawings
- 2. Two bound manuals of all documents.
  - a. Operations and Maintenance Manual including start up procedures.
  - b. Recommended spare parts.
  - c. Written description of the tuning procedure.
  - d. Written description of lance inspection & cleaning procedure.
- 3. Proposed schedule of values and project schedule

**E. COMMON**

- 1. Materials, drawings, engineering design
- 2. Certified TA and Commissioning
- 3. Removal, disposal, and installation by the contractor shall include the safe and proper use and mobilization of equipment or machinery such as cranes, lifting beams, spreader bars, special slings and cables, forklifts, scaffolding and welders that are needed for the work to be done.
- 4. Proper skilled and trained laborers and operators will be provided by the contractor.
- 5. The contractor must also comply with any regulations regarding safe and environmentally-sound disposal of waste materials.
- 6. Other contractors will be working on the units during the outage. Coordination and cooperation to not hinder any of the required work will be needed.
- 7. Replace any hardware damaged during construction as required.

## F. MANUFACTURING REQUIREMENTS

1. All equipment supplied by the Seller shall be manufactured in one complete assembly or in sub-assemblies. All assemblies shall be designed and manufactured to enable the largest pieces possible to be shipped to the plant site.
2. All equipment shall be designed and constructed to minimize field welding. Where field welding is required, all joints shall be prepared for welding before shipment.
3. Preparation for shipment. All items shall be preserved, sealed, and packed suitable for a minimum of 6 months of field storage.
4. Nameplate. A permanently attached corrosion resistant nameplate shall be affixed at a prominent location near the lances shall include the following information as a minimum:
  - a. Name of Manufacturer
  - b. Equipment Type / Name

## 2. **WORK PERFORMED BY JEA**

- a. Supply of limited, temporary electric power (480v 3phase and 120v) and auxiliary air if needed.
- b. Lock out tag out of affected systems.
- c. Limited I&C support for any instrumentation and piping that may need to be temporarily removed from units during AIG upgrade and tuning grid installation. This will be termination/de-termination of existing items. Contractor to remove/replace.
- d. Identification of plant laydown area. (Approximate size of laydown requirements should be supplied by contractor)

## G. DRAWING REFERENCES:

SCR Catalyst Module  
 Internal Structure General Arrangement  
 SCR Assembly Diagram  
 Spool Duct Casing Ass'y Diagram  
 Catalyst Support Structure GA  
 Roof Liner Layout

SCR Cat 201A008.pdf  
 SCR Cat 541M004.pdf  
 SCR Assembly 201A122.pdf  
 SCR Spool Duct 201A120.pdf  
 Cat Support 541M006.pdf  
 HRSG Roof Liner Layout 201A063.pdf



Cat Support  
541M006.pdf



SCR Cat  
201A008.pdf



SCR Cat  
541M004.pdf



SCR Assembly  
201A122.pdf



SCR Spool Duct  
201A120.pdf



HRSG Roof Liner  
Layout 201A063.pdf









