



Procurement Department Bid Section

December 11, 2025

ADDENDUM NUMBER: FOUR (4)

TITLE: 1412069851 (RFP) Construction Services for Miller 230kV Solar Substation

PROPOSAL DUE DATE: December 16, 2025

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA adds the following document to this Solicitation.
 - 1412069851 Addendum 4 - Appendix C – Lighting

There is a change in design capturing the yard lights as well as the perimeter lights. In both cases the photocell is moving from the light fixture to a location on a pole mounted JB. The contractor is to provide the 162W lights (GE ID#WACL010H3AW740NAD1BLCKLRV02 5) as well as the shorting caps (GE ID#PEC0TL).

2. **Question:** For this project, the scheduled start date is based on site work progress and anticipated completion. If there is a delay to the start date, will the completion date extend as well or is the August 21st completion a hard date? Additionally, will JEA entertain alternative schedules?

Answer: The dates provided are hard dates driven by a contract external to the project. The expectation is that those dates will be met.

3. **Question:** Due to the added scope of control cable, foundation, and fence we would like to request an extension for this bid.

Answer: No bid extension will be granted at this time.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.