January 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

15882 Canoe Creek Dr
Jacksonville, FL 32218
1/10/2026 @ 9:15 PM
Estimated gallons released: 200
Action Taken: Washed down and vacuumed impact area. Sampling began 1/11/2026.
Preliminary Cause: Grease

7300 Buffalo Ave
Jacksonville, FL 32208
1/12/2026 @ 8:30 AM
Estimated gallons released: 20500
Action Taken: Pipe replaced. Recovered sewer. Washed down impacted areas. No sampling due to inaccessibility to the river.
Preliminary Cause: Pipe Failure

10690 Beach Blvd
Jacksonville, FL 32246
1/13/2026 @ 8:40 PM
Estimated gallons released: 7000
Action Taken: Pipe replaced. Recovered sewer. Washed down impacted areas. No waterways impacted.
Preliminary Cause: Pipe Failure

6801 Blanding Blvd
Jacksonville, FL 32244
1/15/2026 @ 12:00 PM
Estimated gallons released: 12000
Action Taken: Storm swale and road were vacuumed up. Road was washed down and swale had hydrated lime applied.
Preliminary Cause: Other

3180 Philips Hwy
Jacksonville, FL 32207
1/21/2026 @ 11:22 AM
Estimated gallons released: 600
Action Taken: Removed blockage. Washed down impacted area. Recovered sewer. Spread hydrated lime. Sampling begins 1/22/26.
Preliminary Cause: Blockage

5802 Harris Ave
Jacksonville, FL 32211

1/31/26 @ 10:52 PM
Estimated gallons released: 160000
Action Taken: Road way and plant vacuumed up and washed down, once the temperatures no longer caused equipment to freeze up.
Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

6671 Epping Forest Way N
Jacksonville, FL 32217
1/4/2026 @ 6:13 PM
Estimated gallons released: 100
Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

4506 San Juan Ave
Jacksonville, FL 32210
1/15/2026 @ 6:00 PM
Estimated gallons released: 300
Action Taken: Catch basin and storm swale vacuumed out and lime applied to affected ground.
Preliminary Cause: Equipment Failure

4506 San Juan Ave
Jacksonville, FL 32210
1/17/2026 @ 10:30 AM
Estimated gallons released: 400
Action Taken: Replaced pipe. Recovered sewer out of swale and catch basin. Washed down area.
Preliminary Cause: Pipe Failure

5802 Harris Ave
Jacksonville, FL 32211
1/20/26 @ 11:25 AM
Estimated gallons released: 100
Action Taken: Vac trucks sprayed down the area and recovered from ditch
Preliminary Cause: Contractor Error

757 Eagle Point Dr
Jacksonville, FL 32092
1/23/26 @ 5:42 PM
Estimated gallons released: 800
Action Taken: Vacuumed and washed down impacted roadway.
Preliminary Cause: Blockage

65 Sentosa Dr
St. Johns, FL 32259

1/27/26 @ 4:00 PM
Estimated gallons released: 200
Action Taken: Road washed down and vacuumed up, and storm drains vacuumed out.
Preliminary Cause: Equipment Failure

450 Arlington Rd N
Jacksonville, FL 3211
1/27/26 @ 6:00 PM
Estimated gallons released: 50
Action Taken:
Preliminary Cause: Equipment Failure

7099 Collins Rd
Jacksonville, FL 32244
1/29/26 @ 11:00 PM
Estimated gallons released: 100
Action Taken: Road washed down after repairs were made.
Preliminary Cause: Equipment Failure

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

4905 San Pablo Rd South
Jacksonville, FL 32224
1/5/2026 @ 10:47 AM
Estimated gallons released: 30
Action Taken: Road washed down and all wash water recovered.
Preliminary Cause: Pipe Failure

10304 Briarcliff Rd E
Jacksonville, FL 32218
1/24/26 @ 12:41 PM
Estimated gallons released: 10
Action Taken: NA
Preliminary Cause: Grease

Other Events Reported To The State Watch Office

None

February 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

11180 Vera Dr
Jacksonville, FL 32218
2/2/2026 @ 9:20 AM
Estimated gallons released: 200
Action Taken: Washed down and vacuumed impact area. Sampling began 2/3/2026.
Preliminary Cause: Grease

1250 Imeson Park Blvd
Jacksonville, FL 32218
2/6/2026 @ 11:55 AM
Estimated gallons released: 2000
Action Taken: Washed down and vacuumed impact area. Sampling began 2/7/2026.
Preliminary Cause: Broken

96237 Amelia Concourse
Yulee, FL 32097
2/7/2026 @ 7:00 PM
Estimated gallons released: 2000
Action Taken: Washed down and vacuumed impact area. Sampling began 2/11/2026
Preliminary Cause: Pipe Failure

5535 Moret Dr E
Jacksonville, FL 32244
2/11/2026 @ 4:00 PM
Estimated gallons released:1100
Action Taken: Pipe replaced. Sewer recovered from stormwater channel. Sampling begins 2/12/2026.
Preliminary Cause: Broken

13208 Moby Dick Dr W
Jacksonville, FL 32218
2/12/2026 @ 8:30 PM
Estimated gallons released: 71000
Action Taken: Pipe replaced. Sewer recovered in creek. Sampling began 2/13/2026.
Preliminary Cause: Broken

6927 Hanson Dr N
Jacksonville, FL 32210
2/13/2026 @ 12:19 PM
Estimated gallons released: 10100
Action Taken: Blockage removed. Sewer recovered in woods. Spread lime. Impacted areas

washed down. Sampling begins 2/14/26.
Preliminary Cause: Blockage

10383 Scott Mill Rd
Jacksonville, FL 32257
2/13/2026 @ 1:00 PM
Estimated gallons released: 600
Action Taken: Blockage removed. Unable to recover sewer due to location. Spread lime. Sampling begins 2/14/26.
Preliminary Cause: Blockage

1721 University Blvd N
Jacksonville, FL 32211
2/15/2026 @ 3:36 PM
Estimated gallons released: 4000
Action Taken: Pipe replaced. Sewer recovered in pit. Area washed down. Sampling begins 2/16/26.
Preliminary Cause: Broken

1646 W 45th St
Jacksonville, FL 32208
2/26/2026 @ 11:51 AM
Estimated gallons released: 800
Action Taken: Removed dirt from impact area. Sampling began 2/27/2026.
Preliminary Cause: Grease

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

2434 N Pearl St
Jacksonville, FL 32206
2/2/26 @12:40 PM
Estimated gallons released: 50
Action Taken: Wash and recover.
Preliminary Cause: Other

4334 E Castlewood Dr
Jacksonville, FL 32206
2/3/2026 @ 4:31 PM
Estimated gallons released: 50
Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

2004 Figaro Ln
Jacksonville, FL 32210
2/3/2026 @ 9:30 PM
Estimated gallons released: 100

Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

646 E 31st St
Jacksonville, FL 32206
2/4/2026 @ 3:36 PM
Estimated gallons released: 100
Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

6008 Jammes Rd
Jacksonville, FL 32244
2/12/2026 @ 10:25 AM
Estimated gallons released: 50
Action Taken: Turned off ARV. ARV replaced. Sewer recovered.
Preliminary Cause: Failed ARV

1555 Millcoe Rd
Jacksonville, Fl 32225
2/12/2026 @ 10:27 AM
Estimated gallons released: 900
Action taken: Sewer recovered. Pipe replaced.
Preliminary Cause: Equipment Failure

103 Trout River Dr
Jacksonville, FL 32208
2/12/2026 @ 1:19 PM
Estimated gallons released: 300
Action Taken: Sewer recovered. Pumps refueled and replaced.
Preliminary Cause: Third Party

1292 Peacefield Dr
Jacksonville, FL 32205
2/17/2026 @ 2:24 PM
Estimated gallons released: 50
Action Taken: Line jetted to clear blockage. Area washed down with disinfectant.
Preliminary Cause: Blockage

7800 Delaroache Dr
Jacksonville, FL 32210
2/18/2026 @ 7:55 AM
Estimated gallons released: 50
Action Taken: Pipe replaced
Preliminary Cause: Third Party

8507 Belfort Lndg Dr
Jacksonville, FL 32216

2/25/2026 @ 10:42 AM
Estimated gallons released: 50
Action Taken: Full recovery was made. Street was washed down and recovered.
Preliminary Cause: Blockage

850 Aries Rd W
Jacksonville, FL 32216
2/27/2026 @ 9:17 AM
Estimated gallons released: 50
Action Taken: Washed down and vacuumed impact area. Sampling began 2/28/2026.
Preliminary Cause: Blockage

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

8819 Brier Way N
Jacksonville, FL 32221
2/10/2026 @ 12:46 PM
Estimated gallons released: 10
Action Taken: Blockage removed. Sewer recovered. Area washed down.
Preliminary Cause: Blockage

8885 Scott Woods Dr E
Jacksonville, FL 32208
2/10/2026 @ 4:14 PM
Estimated gallons released: 10
Action Taken: Blockage removed. Sewer recovered. Area washed down.
Preliminary Cause: Blockage

7612 Plumwood Dr
Jacksonville, FL 32256
2/22/2026 @ 5:05 PM
Estimated gallons released: 20
Action Taken: Cleared blockage.
Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

536 Saddlestone Dr
Jacksonville, FL 32259
2/24/2026 @ 10:00 PM
Estimated gallons released: 5000

Action Taken: Throttled main down and replaced saddle then tied back into long side poly.
Preliminary Cause: Broken

8752 Bayleaf Rd
Jacksonville, FL 32256
2/28/2026 @ 7:00 AM
Estimated gallons released: 50
Action Taken: Contractor coordinated cleanup efforts.
Preliminary Cause: Contractor Error

March 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

9119 Tamworth Rd
Jacksonville, FL 32208
3/14/2026 @ 2:36 PM
Estimated Gallons Released: 1500
Action Taken: Road cleaned, full recovery no waters impacted
Preliminary Cause: Grease

1102 Mc Conihe St
Jacksonville, FL 32209
3/25/26 @ 2:00 PM
Estimated Gallons Released: 5000
Action Taken: Impacted areas washed down. Sewer recovered from storm drains and in system. No waterways impacted.
Preliminary Cause: Third Party

I-95 and CR 108
Yulee, FL 32097
3/31/26 @ 10:40 AM
Estimated Gallons Released: 18700
Action Taken: Sewer recovered from impacted land. No waterways impacted.
Preliminary Cause: Third Party

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

310 Ridgecrest Ln
Jacksonville, FL 32259
3/4/2026 @ 6:08PM
Estimated gallons released: 100
Action Taken: Recover from storm drain. Wash down impacted areas

Preliminary Cause: Blockage

9540 San Jose Blvd
Jacksonville, FL 32257
3/11/2026 9:46 AM
Estimated Gallons Released: 100
Action Taken: Closed valve. Washed down road and recovered. No waterways impacted.
Preliminary Cause: Failed ARV

4100 Baymeadows Rd
Jacksonville, FL 32217
3/17/2026 @5:20 PM
Estimated gallons released:100
Action Taken: Pipe fixed. Washed down road and recovered.
Preliminary Cause:ARV

11525 Village Crossing Dr
Jacksonville, FL 32256
3/18/2026 10:42 AM
Estimated Gallons Released: 400
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Debris

12426 W Beaver St
Jacksonville, FL 32209
3/20/2026 8:45 AM
Estimated Gallons Released: 200
Action Taken: Washed down impacted area
Preliminary Cause: Grease

3780 University Club Blvd
Jacksonville, FL 32277
3/20/2026 10:00 AM
Estimated Gallons Released: 500
Action Taken: Washed down impacted area
Preliminary Cause: Broken

796 Sailor Grove Ln
Jacksonville, FL 32221
3/31/2026 7:55 AM
Estimated Gallons Released: 100
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Debris

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

1840 Cedar Bay Rd
Jacksonville, FL 32218
3/3/2026 @ 9:45 AM
Estimated gallons released: 3700
Action Taken: Bypass was opened back up to stop spill. Recovered partially treated sewer in plant. Washed down impacted areas. Spread lime.
Preliminary Cause: Equipment Failure

April 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

6405 Cooper Ln
Jacksonville, FL 32210
4/8/2026 @ 3:30 PM
Estimated gallons spilled: 300
Action Taken: Blockage removed. Sampling began 4/9/2026.
Preliminary Cause: Blockage

118th St and Faulkner Dr
Jacksonville, FL 32244
4/8/2026 @ 7:00 PM
Estimated gallons spilled: 200
Action Taken: Blockage removed. Washed down road. Recovered sewer. Sampling began 4/9/2026.
Preliminary Cause: Blockage

3945 San Jose Park Dr
Jacksonville, FL 32217
4/10/2026 @ 2:00 PM
Estimated gallons spilled: 3000
Action Taken: Pipe replaced. Recovered sewer in pit and storm drain. No waterways impacted.
Preliminary Cause: Third Party

7070 Salamanca Ave
Jacksonville, FL 32217
4/14/2026 @ 12:00 PM
Estimated gallons spilled: 610
Action Taken: Pipe replaced. Recovered sewer from drainage ditch and flushed. Sampling began 4/14
Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

4009 Corrientes Ct E
Jacksonville, FL 32217
4/2/2026 @ 9:51 AM
Estimated gallons spilled: 100
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Blockage

5632 Falcon St W
Jacksonville, FL 32244
4/9/2026 @ 2:20 PM
Estimated gallons spilled: 50
Action Taken: Blockage removed. Recovered sewer. Washed down road. Spread lime. No waterways impacted.
Preliminary Cause: Blockage

710 Haines St
Jacksonville, FL 32202
4/23/2026 @ 12:19 PM
Estimated gallons spilled: 250
Action Taken: Blockage removed. Washed down impacted areas. Recovered sewer from storm drain. No waterways impacted.
Preliminary Cause: Blockage

211 S Arlington Rd
Jacksonville, FL 32216
4/23/26 @ 4:30 PM
Estimated gallons spilled: 200
Action Taken: Recovered sewer.
Preliminary Cause: Third Party

11078 Skylark Dr
Jacksonville FL 32257
Event Date: 4/28/2026 @ 12:00 PM
Estimated gallons spilled: 150
Action Taken: Washed down and made full recovery. No waterways impacted
Preliminary Cause: Valve

6983 103rd St
Jacksonville FL 32210
Event Date: 4/28/2026 @ 4:01 PM
Estimated gallons spilled: 100
Action Taken: Washed down and recovered. No waterways impacted
Preliminary Cause: Pipe Failure

1499 Zoo Pkwy
Jacksonville FL 32218
Event Date: 4/30/2026 @ 7:16 AM
Estimated gallons spilled: 100
Action Taken: Blockage cleared. No waterways impacted.
Preliminary Cause: ARV

Minor SSO Events
JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7434 Everett Frst Dr
Jacksonville, FL 32219
Event Date: 4/16/26 @ 11:00 AM
Estimated gallons spilled: 10
Action Taken: Washed down road and recovered.
Preliminary Cause: Blockage

1615 Chateau Dr
Jacksonville, FL 32221
Event Date: 4/28/26 @ 4:10 PM
Estimated gallons spilled: 10
Action Taken: Rinsed down and recovered
Preliminary Cause: Blockage

May 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4733 Mandarin Station Dr N
Jacksonville, FL 32257
5/1/2026 @ 9:00 AM
Estimated gallons spilled: 1000
Action Taken: Rinsed down and recovered. Sampling began 5/2/2026.
Preliminary Cause: Pipe Failure

3742 Southside Blvd
Jacksonville, FL 32216
5/18/2026 @ 5:00 AM
Estimated gallons spilled: 1000
Action Taken: Rinsed down and recovered. No surface water impacted
Preliminary Cause: Failed ARV

9955 Merlin Dr E
Jacksonville, FL 32257
5/19/2026 @ 6:20 PM
Estimated gallons spilled: 69900
Action Taken: Pipe repaired. Recovered sewer out of pit and storm drains. Spread hydrated lime. Washed down impacted areas. Sampling begins 5/21/2026.
Preliminary Cause: Broken

6370 Sauterne Dr
Jacksonville FL 32210
5/28/2026 1:28:00 PM
Estimated gallons spilled: 300
Action Taken: Rinse down curb and sidewalk and recover from cleanup. Sampling begins 5/29/2026
Preliminary Cause: Broken

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

7019 San Fernando Pl
Jacksonville FL 32217
Event Date: 5/1/2026 @ 11:38 AM
Estimated gallons spilled: 100
Action Taken: Full Recovery
Preliminary Cause: Pipe Failure

661 Riverside Ave
Jacksonville, FL 32202
Event Date: 5/5/2026 @ 11:40 AM
Estimated gallons spilled: 100
Action Taken: Recovered sewer. Washed down impacted area.
Preliminary Cause: Blockage

5420 Tellaro Ln
Jacksonville, FL 32210
Event Date: 5/7/2026 @ 10:09 PM
Action Taken: Pipe replaced. Washed down curb. Recovered sewer.
Preliminary Cause: Third Party

96237 Amelia Concourse
Yulee, FL 32097
Event Date: 5/11/2026 @ 8:00 AM
Action Taken: Turned off ARV.
Preliminary Cause: Failed ARV

576 Hawthorn Park Cir
Yulee, FL 32097
Event Date: 5/25/2026 @ 4:47 PM
Estimated gallons spilled: 300
Action Taken: Recovered sewer. Washed down impacted area.
Preliminary Cause: Third party

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

N Julia St and Church St
Jacksonville, FL 32202
Event Date: 5/7/2026 @ 11:35 AM
Estimated gallons spilled: 10
Action Taken: Blockage removed. Washed down impacted area and recover sewer.
Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

None

June 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

6939 Magdelena Dr
Jacksonville, FL 32210
6/2/2026 9:00 AM
Estimated gallons released: 200
Action Taken: Washed down street and curb. Recovered sewer from storm drain.
Preliminary Cause: Grease

1089 Day Ave
Jacksonville, FL 32205
6/3/2026 6:15 PM

Estimated gallons released: 250
Action Taken: Blockage removed. Recovered sewer from street. Washed down impacted areas.
Preliminary Cause: Grease

6700 Bowden Rd
Jacksonville, FL 32216
6/15/2026 7:15 PM
Estimated gallons released: 1050
Action Taken: Blockage removed. Washed down and recovered from street. Sampling begins 6/15.
Preliminary Cause: Grease

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

W 16th St and Jupiter Ave
Jacksonville, FL 32206
6/3/2026 4:01 PM
Estimated gallons released: 100
Action Taken: Blockage removed. Recovered sewer. Washed down road.
Preliminary Cause: Grease

14217 Pecan Park Rd
Jacksonville, FL 32218
6/4/2026 1:25 PM
Estimated gallons released: 500
Action Taken: Valve turned off. Replaced ARV. Recovered sewer from manhole and street. Washed down impacted areas. Spread hydrated lime.
Preliminary Cause: Failed ARV

5107 San Jose Blvd
Jacksonville, FL 32207
6/22/2026 1:25 PM
Estimated gallons released: 500
Action Taken: Replaced new valve and sleeve on pipe. Recovered sewer from pipe and hole. Washed down impacted areas. No waterways impacted.
Preliminary Cause: Pipe Failure

3116 Falconer Dr
Jacksonville, FL 32223
6/24/2026 12:00 PM
Estimated gallons released: 150
Action Taken: Removed blockage. Washed down impacted areas. No waterways impacted.
Preliminary Cause: Grease
Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

6850 Energy Center Dr
Jacksonville, FL 32256
6/1/2026 10:57 AM
Estimated gallons released: 100
Action Taken: Remove contaminated soil. Seed and hay.
Preliminary Cause: Operator Error

July 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7621 Centurion Pkwy N
Jacksonville, FL 32256
7/6/26 @ 11:09 AM
Estimated gallons spilled: 13800
Action Taken: Pipe replaced. Recovered sewer from pit, street, and storm drain. Washed down impacted areas. Sampling began 7/7/26. No waterways impacted after investigation.
Preliminary Cause: Pipe Failure

343 Nocatee Parkway (46 Adventure Trail)
St. Johns, FL
7/18/26 @ 3:00 PM
Estimated gallons spilled: 10,000
Action Taken: Pipe repaired. Washed down sidewalk and street. Applied hydrated lime to impacted areas. Sampling began 7/19/26.
Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

7082 Plymouth Grove Ct
Jacksonville, FL 32220

7/4/26 @ 1:30 AM
Estimated gallons spilled: 600
Action Taken: Blockage removed. Recovered sewer from drains. Washed down impacted areas. Sampling began 7/5/26.
Preliminary Cause: Blockage

6950 Morse Ave
Jacksonville, FL 32244
7/9/26 @ 4:30 PM
Estimated gallons spilled: 100
Action Taken: Pipe replaced. No waterways impacted.
Preliminary Cause: Third party

3808 San Remo Dr
Jacksonville, FL 32217
7/31/26 @ 3:00 PM
Estimated gallons spilled: 100
Action Taken: Repaired pipe and spread lime. No waterway impacted
Preliminary Cause: Pipe failure

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7099 Collins Rd
Jacksonville, FL 32244
7/26/26 @ 9:25 PM
Estimated gallons spilled: 10
Action Taken: ARV replaced. No waterways impacted. Recovered sewer from manhole and washed down impacted area.
Preliminary Cause: Failed ARV

Other Events Reported To The State Watch Office

584 Autumn Tide Trail
Nocatee, FL 32081
7/7/26 @ 12:15 PM
Estimated gallons spilled: 5000
Action Taken: Pipe repaired.
Preliminary Cause: Third Party

August 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

Eastport Rd and Rice Rd
Jacksonville, FL 32218
8/11/26 6:50 PM
Estimated gallons spilled: 3,000
Action Taken: Valve repaired. Washed down sidewalk and street. Applied hydrated lime to impacted areas. No waterway impacted.
Preliminary Cause: ARV

Spicebush Dr and Bristlecone Dr
St. Johns, FL 32259
8/14/26 5:00 PM
Estimated gallons spilled: 1,700,000
Action Taken: Valve Shut off. Recover from ditches. Applied hydrated lime to impacted areas. Trout Creek impacted.
Preliminary Cause: Third Party

11127 Lem Turner Rd
Jacksonville, FL 32218
8/18/26 5:08 PM
Estimated gallons spilled: 15,700
Action Taken: ARV replaced. Recovered sewer from street and manhole. Washed down street and sidewalk. Spread lime. Sampling begins 8/19/26.
Preliminary Cause: Failed ARV

10696 Old St Augustine Rd
Jacksonville, FL 32257
8/21/26 12:19 PM
Estimated gallons spilled: 33,550
Action Taken: Pipe replaced. Sewer recovered from excavation pit and street. Washed down street. Sampling began 8/22/26.
Preliminary Cause: Broken

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

2591 Congaree Dr W
Jacksonville FL 32211
8/14/2026 6:00:00 PM
Estimated gallons spilled: 250
Action Taken: wash down and recover
Preliminary Cause: Grease

8537 Royal Lakes Dr
Jacksonville FL 32256
8/16/2026 12:15:00 PM
Estimated gallons spilled: 250
Action Taken: Pipe replaced. Rinse down curb and recover
Preliminary Cause: Pipe Failure

11651 W Ride Dr
Jacksonville, FL 32223
8/19/2026 5:15 PM
Estimated gallons spilled: 200
Action Taken: Blockage removed. Washed down road and recovered sewer out of storm drain. Sampling began 8/20/26.
Preliminary Cause: Blockage

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

4550 Reed Bark Ln
Jacksonville FL 32246
8/14/2026 9:30:00 PM
Estimated gallons spilled: 20
Action Taken: Pipe replaced. Rinse down curb and recover
Preliminary Cause: Debris

Chaffee Rd S and General Ave
Jacksonville FL 32220
8/16/2026 2:30:00 PM
Estimated gallons spilled: 1
Action Taken: Pipe replaced
Preliminary Cause: Third party

Other Events Reported To The State Watch Office

None

September 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

11360 Shady Brook Ln
Jacksonville, FL 32223
9/6/2026 @ 4:14 PM
Estimated gallons released: 250
Action Taken: Pipe repaired. Sampling began 9/7/2026
Preliminary Cause: Pipe Failure

10210 Haley Rd
Jacksonville, FL 32257
9/7/2026 @ 1:49 PM
Estimated gallons released: 1000
Action Taken: Pipe replaced. Recovered sewer from lift station. Washed down impacted areas. No waterways impacted.
Preliminary Cause: Pipe Failure

74 E 32nd St
Jacksonville, FL 32206
9/16/2026 @ 3:30 PM
Estimated gallons released: 5
Action Taken: Release stopped from entering Long Branch Creek. Sampling begins 9/17
Preliminary Cause: ARV

4815 Wesconnett Blvd
Jacksonville, FL 32210
9/26/2026 @ 10:45 AM
Estimated gallons released: 100
Action Taken: Washed down area and spread hydrated lime. Sampling begins 9/27
Preliminary Cause: Broken

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

8531 Walden Glen Dr
Jacksonville, FL 32256
9/8/2026 @ 6:35 PM
Estimated gallons released: 520
Action Taken: Pipe replaced. Recovered sewer in curb and in excavation pit. Driveway removed.
Preliminary Cause: Broken

3775 Ringneck Dr
Jacksonville, FL 32226
9/11/2026 @ 2:50 PM
Estimated gallons released: 400

Action Taken: Blockage removed. Washed down impacted areas. Sewer recovered from storm drain. Sampling began 9/11/2026.
Preliminary Cause: Blockage

3525 Eunice Rd
Jacksonville, FL 32250
9/18/2026 @ 9:42 AM
Estimated gallons released: 50
Action Taken: Turned off valve. Replaced ARV. Sewer recovered. Washed down impacted areas. No waterways impacted.
Preliminary Cause: Failed ARV

Pepsi Ln and Bowden Rd
Jacksonville, FL 32216
9/29/2026 @ 10:15 AM
Estimated gallons released: 150
Action Taken: Pipe replaced. Sewer recovered and washed down impacted areas. No waterways impacted
Preliminary Cause: Broken

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

10349 Piedmont Rd
Jacksonville, FL 32218
9/12/2026 @ 9:30 PM
Estimated gallons released: 10
Action Taken: Blockage removed. Washed down impacted areas. Sewer recovered. No waterways impacted.
Preliminary Cause: Blockage

2933 Canyon Falls Dr E
Jacksonville, FL 32224
9/13/2026 @ 2:50 PM
Estimated gallons released: 10
Action Taken: Pipe replaced. Sewer recovered. Contaminated dirt replaced. No waterways impacted.
Preliminary Cause: Pipe Failure

Other Events Reported To The State Watch Office

None

October 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

- **204 Century 21 Dr**
  Jacksonville, FL 32216
  10/03/2026 @ 4:00 PM
  Estimated gallons released: 200
  Action Taken: Operations notified days later, problem fixed itself. Preventative maintenance will come out and complete further corrective actions. Sampling began 10/5/26.
  Preliminary Cause: Pipe Failure
- **3120 Emerson St**
  Jacksonville, FL 32207
  10/07/2026 @ 9:21 AM
  Estimated gallons released: 255,041
  Action Taken: Pipe replaced. Sewer recovered. Washed down impacted areas. Spread lime. Sampling began 10/9/26.
  Preliminary Cause: Broken
- **2405 Hugh Edwards Dr**
  Jacksonville, FL 32210
  10/07/2026 @ 8:45 PM
  Estimated gallons released: 110,600
  Action Taken: Pipe repaired. Sewer recovered. Washed down impacted areas. Sampling began 10/9/26.
  Preliminary Cause: Broken
- **7932 Southside Blvd**
  Jacksonville, FL 32256
  10/08/2026 1:08 PM
  Estimated gallons released: 172,956
  Action Taken: Valve turned off and ARV replaced. Sewer recovered from manhole, ditch, and storm drain. Washed down impacted areas. Spread lime. Sampling began 10/9/2026.
  Preliminary Cause: Failed ARV
- **11001 Pritchard Rd**
  Jacksonville, FL 32219
  10/09/2026 9:15 AM
  Estimated gallons released: 15,750
  Action Taken: Blockage removed. Bypass pump set up to prevent further sewer releases. Sewer recovered on land, and stormwater conveyance channel. Washed down impacted areas. Spread lime. Sampling begins 10/10/26.
  Preliminary Cause: Cave In
- **10375 Agave Rd**
  Jacksonville, FL 32246
  10/10/26 6:00 PM
  Estimated gallons released: 500
  Action Taken: None
  Preliminary Cause: Equipment Failure
- **12495 Sunchase Dr**
  Jacksonville, FL 32246

10/13/2026 5:05 PM
Estimated gallons released: 5000
Action Taken: Pipe replaced. Washed down and recovered from impacted areas. Sampling begins 10/14/26
Preliminary Cause: Third Party

- **4815 Wesconnett Blvd**
  Jacksonville, FL 32210
  10/14/2026 12:19PM
  Estimated gallons released: 750
  Action Taken: Pipe replaced. Washed down and spread lime to impacted areas. Sampling begins 10/15/26
  Preliminary Cause: Broken
- **245 Lige Branch Ln**
  Jacksonville, FL 32259
  10/14/2026 1:00 PM
  Estimated gallons released: 32,000
  Action Taken: Pipe replaced. Washed down and spread lime to impacted areas. Sampling begins 10/16/26
  Preliminary Cause: Pipe Failure
- **10906 Falkland Rd**
  Jacksonville, FL 32221
  10/14/2026 4:58 PM
  Estimated gallons released: 2,000
  Action Taken: Pipe replaced. Washed down and recovered from impacted areas.
  Preliminary Cause: Pipe Failure
- **11066 Traci Lynn Dr**
  Jacksonville, FL 32218
  10/23/2026 @ 7:00AM
  Estimated gallons released: Unknown
  Action Taken: Cleaning and replacement of damaged property.
  Preliminary Cause: Back up into customer's home
- **2239 Lou Dr W**
  Jacksonville, FL 32216
  10/30/2026 @ 8:10 PM
  Estimated gallons released: 2000
  Action Taken: Pipe replaced. Sewer recovered. Washed down impacted areas. Sampling began 10/31/26.
  Preliminary Cause: Cave In

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

- **1647 E 16th st**
  Jacksonville, FL 32206
  10/02/2026 @ 10:30 AM
  Estimated gallons released:100
  Action Taken: Blockage cleared, washed down impacted areas. No waterways impacted
  Preliminary Cause: Blockage

- **600 N Main St**
  Jacksonville, FL 32202
  10/02/2026 @ 11:15 AM
  Estimated gallons released: 50
  Action Taken: Blockage cleared, washed down impacted area. No waterways impacted
  Preliminary Cause: Blockage
- **11891 Hidden Hills Dr S**
  Jacksonville, FL 32225
  10/11/2026 2:00 PM
  Estimated gallons released: 300
  Action Taken: Yard vacuumed and hydrated lime applied.
  Preliminary Cause: Blockage
- **156 Sutton Dr**
  Ponte Vedra, FL 32081
  10/13/2026 @ 9:04 PM
  Estimated gallons released: 150
  Action Taken: Blockage cleared, washed down impacted area. No waterways impacted
  Preliminary Cause: Blockage
- **3725 Philips Hwy**
  Jacksonville, FL 32207
  10/14/2026 @ 1:12 PM
  Estimated gallons released: 60
  Action Taken: ARV replaced and overflow was contained to ditch. No waterways impacted
  Preliminary Cause: ARV
- **1021 Hillock Dr E**
  Jacksonville, FL 322021
  10/16/2026 @ 7:43 PM
  Estimated gallons released: 100
  Action Taken: Pipe replaced. Washed down and recovered from impacted areas. No waterways impacted
  Preliminary Cause: Broken
- **1433 Talleyrand Ave**
  Jacksonville, FL 32206
  10/21/2026 @ 3:28 PM
  Estimated gallons released: 100
  Action Taken: Pipe replaced. Washed down and recovered from impacted areas. No waterways impacted
  Preliminary Cause: Broken
- **147 Wagonbrook Wy**
  Jacksonville, FL 32259
  10/22/2026 @ 9:13 AM
  Estimated gallons released: 50
  Action Taken: Washed down and recovered from impacted areas. No waterways impacted.
  Preliminary Cause: ARV
- **10531 Busch Dr**
  Jacksonville, FL 32218
  10/28/2026 @ 11:55 AM
  Estimated gallons released: 500

Action Taken: Valve shut off. Washed down and recovered impacted areas. No waterways impacted.
Preliminary Cause: Pipe Failure

- **9927 Atlantic Blvd**
  Jacksonville, FL 32225
  10/28/2026 @ 6:00 PM
  Estimated gallons released: 100
  Action Taken: Blockage removed. Washed down impacted areas and sewer recovered. No waterways impacted.
  Preliminary Cause: Blockage
- **5802 Harris Ave**
  Jacksonville, FL 32211
  10/29/2026 @ 8:00 AM
  Estimated gallons released: 200
  Action Taken: Pipe repaired. Sewer recovered. No waterways impacted.
  Preliminary Cause: Pipe Failure
- **32 E 45th St**
  Jacksonville, FL 32208
  10/29/2026 @ 9:00 AM
  Estimated gallons released: 100
  Action Taken: Lateral rerouted. Sewer recovered. Washed down impacted areas. No waterways impacted.
  Preliminary Cause: Pipe Failure

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

- **4832 N Main St**
  Jacksonville, FL 32206
  10/05/2026 10:40 AM
  Estimated gallons released: 5
  Action Taken: Line cleared. Sewer recovered. Impacted areas washed down. No waterways impacted.
  Preliminary Cause: Equipment Failure
- **11891 Hidden Hills Dr S**
  Jacksonville, FL 32225
  10/11/2026 2:00 PM
  Estimated gallons released: 300

- **53 Ponte Vedra Blvd**
  Ponte Vedra Beach, FL 32082
  10/16/2026 10:00 AM
  Estimated gallons released: 10
  Preliminary Cause: Equipment Failure

Other Events Reported To The State Watch Office

- **5671 Seaboard Ave**
  Jacksonville, FL 32244
  10/07/2026 3:00 AM
  Estimated gallons released: 12
  Action Taken: Transformer replaced. Boom placed in drainage ditch. Contractor placed more boom and will properly discard them. Will monitor vegetation and parking lot for staining.
  Preliminary Cause: Equipment Failure